

GENERAL

1. This document provides detailed information on how to install and operate the SLT Series of Surge Protection Devices (SPD).
2. Incorrect installation may significantly impair the performance of the SPD. It is particularly important that all installation procedures and guidelines be followed exactly.
- 3. INSTALLATION OF THIS SPD SHOULD ONLY BE PERFORMED BY A QUALIFIED INSTALLER.**
4. CHECK TO ENSURE THAT ALL CONNECTIONS ARE CORRECT AND SECURE BEFORE ENERGIZING.
5. KEEP THIS MANUAL IN A SAFE, DRY PLACE FOR FUTURE REFERENCE.

WARRANTY INFORMATION

Meter-Treater, Inc. (MTI) warrants all SLT Series models to be free from defects, and will at our option repair or replace the product should it fail within three (3) years from the first date of shipment. This warranty is limited to defects in workmanship or materials, and does not cover customer damage, abuse or unauthorized modification. If this product fails or does not perform as specified, your sole recourse shall be repair or replacement as described above. Under no condition shall MTI be liable for any damages incurred by the use of this product. Damages include, but are not limited to, the following: lost profits, lost savings and incidental or consequential damages arising from the use of or inability to use this product. MTI specifically disclaims all other warranties, expressed or implied, and the installation or use of this product shall be deemed an acceptance of these terms by the user.

WARRANTY RETURNS

All warranty and non-warranty repairs must be returned freight prepaid and insured to MTI. All returns must have a Return Authorization (RA) number on the outside of the shipping container. This number may be obtained from MTI Warranty Department (800) 342-6890. Products returned without an RA number will not be accepted.

IF UNIT(S) ARE RECEIVED DAMAGED,
NOTIFY THE SHIPPING COMPANY
IMMEDIATELY. RETAIN ALL SHIPPING
CONTAINERS AND PACKING MATERIALS FOR
INSPECTION.

Please Note:
There are no user serviceable parts inside.



Meter-Treater, Inc.
1349 South Killian Drive • Lake Park, FL 33403
Phone: 561.845.2007 • Fax: 561.848.2372
Email: sales@metertreater.com
Website: www.metertreater.com

SLT DIN Series Surge Protection Device

USER MANUAL AND INSTALLATION GUIDE



COMMERCIAL INSTALLATIONS

CAUTION

IMPORTANT SAFETY INSTRUCTIONS

1. Never install communication wiring during a lightning storm.
2. This SPD is for INDOOR USE ONLY.
3. SLT Series suppressors are intended for use as primary protectors for power and/or data lines.
3. Read and understand all instructions prior to installation and operation.

WARNING

Should your equipment or building be subject to a direct lightning strike, this SPD will not provide complete protection.

NOTE: If applicable, the protected device/equipment should also have AC protection because it is still vulnerable to transients on the power lines. Omitting AC protection poses a continued threat of failures at the communication interface.

GROUNDING

The SPD's ground stud must be connected to the ground reference used by the system being protected. In a computer room environment this grounding point may be the ground bar in the AC power panel. Ground leads longer than 12" are not recommended.

Grounding is accomplished on the 4 wire SPD's via any of the four corner securing screws on the SPD. When the din rail clip is used it will pick up a ground connection becoming part of the unit's ground. A ground lug is also provided and can accommodate up to a #10AWG ground wire. The ground lug can be secured to any one of the four corner screws in order to obtain a ground point.




Grounding is accomplished on the 12 and 24 wire units via the ground lug which is located on the top of the SPD. Surge protection devices must not be connected to ground points that are independent of AC ground.

NOTE: It is always best to test grounds to verify their existence before relying on them to protect sensitive equipment.

PERFORMANCE NOTE

The grounding wire must be as short as possible. Minimize length to the centimeter/inch and use a minimum of #14 AWG wire.

DIMENSIONS



INSTALLATION

The SLT DIN Series of products are easy to install. The following instructions clearly explain each step:

NOTE: Make sure to follow installation instructions exactly; if the SPD is improperly installed, the current limiting feature could be rendered inoperable.

1. Connect the Load (protected) side of the SLT DIN Series product to your equipment using straight wire hookups as short as possible.
2. Connect the incoming (unprotected) wires/cable to the Line (unprotected/exposed) side of the SLT DIN Series product.
3. Connect a #14 AWG ground wire from the SLT ground stud and secure it to the nearest available chassis ground.